

General Environmental Incident Summary

Incident: 4012 **Date/Time Notice:** 1/29/2016 1311 **DEM Incident No:**

Responsible Party: n/a

Date Incident: 1/29/2016 **Time Incident:** 1000 **Duration:**

County: Ward **Twp:** 155 **Rng:** 82 **Sec:** 19 **Qtr:**

Lat: 48.22897 **Long:** -101.25300 **Method:** Interpolation from map

Location Description: Kum and Go #816- 2626 E Burdick Expressway, Minot

Submitted By: Amy Flaherty

Affiliation: Seneca Companies

Address: 4140 E 14th St

City: Des Moines

State: IA

Zip: 50313

Received By:

Contact Person:

2626 E Burdick Expressway
Minot, ND

Distance Nearest Occupied Building:

Release Contained: Yes

Type of Incident: Tank Overflow

Description of Released Contaminant: Super unleaded fuel

Volume Spilled: 3.00 gallons

Ag Related: No

EPA Extremely Hazardous Substance: Unknown

Reported to NRC: Unknown

Cause of Incident:

Automatic shutoff did not engage while customer was fueling vehicle. Approximately 2-3 gallons was spilled.

Risk Evaluation:

none

of Fatalities:

of Injuries:

Affected Medium: 06 - water and air

Potential Environmental Impacts:

Potential impact to water. Advised manager of gas station to let us know if customers/neighbors complain of vapors.

Action Taken or Planned:

A small amount of fuel reached a storm drain on site. A maintenance technician assessed the drain and concluded that it had evaporated. Spill on concrete was cleaned with floor dry.

Wastes Disposal Location:

Agencies Involved:

Updates

Date: 1/29/2016 ***Status:*** Reviewed - No Action Required

Author: Crowdus, Kory

Updated Volume:

Notes:

Due to the small amount released and rapid response and cleanup, no further follow-up is required.